

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212838
Address: 528 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Robb Popp	Failed	Monday, February 28, 2022

Corrective Action Required:

1	Misc	GAS LINE BOND REQUIRED -MUST BE BONDED TO ELECTRICAL SERVICE GROUNDING ELECTRODE SYSTEM
---	------	--

Comments: