

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203845
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Failed	Monday, February 28, 2022

Informational:

1 Misc

-S100 OK FOR USE TO STORE EQUIPMENT

Informational:

2 Misc

Meet on site with Mike Weissenbach of the Fire Department to determine if the NW ball field could be utilized for the senior night game on October 4th. All life safety, access and parking requirements are being met for this location. Protective fencing is being installed to separate the construction area off. Portable facilities will be provided. Staff will be on site to provide additional safety.

The NW field is being released to be used for its intended purposes in the afternoon and early evening on Monday, October 4th, 2020.

Mike Weisenborn 09/29/2021 3:48 PM

Corrective Action Required:

3 Misc

2/28/22 INSPECTION OF REMAINING FIELDS AND NORTH ATHLETIC COMPLEX FOR TCO

-PROVIDE PERMANENT SIGNAGE AT ELECTRICAL ROOM DOOR
-PROVIDE ANTI SIPHON DEVICE AT HOSE BIB
-COMPLETE WATER AND SANITARY

Comments: