

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214054
Address: 4716 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Not Ready	Tuesday, March 01, 2022

Corrective Action Required:

1	Misc	-Fb gaps at vertical fire blockings. Use 3/4" sheathing for fire blocking; vertical fire blockings must be no more than ten ft apart, including wall space above windows. **fb gaps at vertical fire blockings. Use 3/4" sheathing or other approved material **Look at the gaps at top and bottom of the vertical fire blockings. Please close these gaps with proper material, like insulation, etc -Fb basement bedroom 4 wall from closet soffit **pack insulation in gap **OK TO INSULATE **2/9/22-THIS IS A 2ND FAILED INSPECTION **2/16/22-REINSPECTION FEE ASSESSED **2/22/22-REINSPECTION FEE ASSESSED **2/25/22-REINSPECTION FEE ASSESSED **3/1/22-REINSPECTION FEE ASSESSED
---	------	--

Comments:

