

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213818  
Address: 4720 NE FREEHOLD DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Not Ready	Tuesday, March 01, 2022

Corrective Action Required:

1	Misc	-Deck beam not double 2x12 as shown on plan. Deck posts are required to be notched for beam attachment with two 1/2" through bolts or equivalent. **Install two 1/2" through bolts or equivalent at each beam-post connection  -Fb wall in basement bedroom closet wall and bathroom wall from ceiling space  **OK TO INSULATE **2/22/22-THIS IS A 2ND FAILED INSPECTION **2/25/22-NOT READY FEE ASSESSED **3/1/22-NOT READY FEE ASSESSED  **I NEED TO MEET WITH SOMEONE HERE WITH A FIRE-BLOCKING FOAM CAN AND A FEW PIECES OF INSULATION. LETS GET THIS THING DONE
---	------	--

Comments: