

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213123  
Address: 130 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Not Ready	Tuesday, March 01, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE ADDRESS 3/1/22 Fire block HVAC soffit north basement & bed 4 ( 3/1/22 not done ) CONNECT GAS LINE AT FIREPLACE ( seal upward penetration fireplace floor (3/1/22) PROVIDE MIN 10 PSI FOR 15 MINUTES ( pressure steady at 25 psi)
---	--------------------------	--

Comments: