

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212835
Address: 3108 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, March 01, 2022

Corrective Action Required:

1	Misc	-Seal top plate penetration bed room 2 -cs-pf per design and plans at all locations see exterior -install and complete all exterior doors and windows -joist hangers required at stair landing where bearing ends did two still one needed
---	------	---

Okay to insulate DO NOT COVER ANY ITEMS STILL NEEDING INSPECTION

Comments: