

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210880
Address: 2118 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, March 01, 2022

Corrective Action Required:

1	Miscellaneous Correction	SUBMIT BACKFLOW CERTIFICATION FOR LAWN IRRIGATION PERMIT PROVIDE SOD & SPLASH BLOCKS PROVIDE GUARDRAIL FRONT STOOP OR RAISE GRADE TO LESS THAN 30" PROVIDE HARDWARE FRONT DOOR REMOVE DUST COVERS SMOKE DETECTORS SUMP SHALL DISCHARGE 36" FROM FOUNDATION
---	--------------------------	---

Comments: