CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212553

Address: 3105 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Tuesday, March 01,

Residential 2022

Corrective Action Required:

1 Misc -protect NM within 6' of attic access

-fire block hvac chase

-bed 5 windows to be installed

-egress window in basement to be installed

-jacuzzi tub motor and outlet to be accessible for service at time of finish per

code

-fire block bath one ceiling line

Comments: