

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212553  
Address: 3105 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, March 02, 2022

Corrective Action Required:

1	Misc	-protect NM within 6' of attic access -fire block hvac chase -bed 5 windows to be installed -egress window in basement to be installed -jacuzzi tub motor and outlet to be accessible for service at time of finish per code -fire block bath one ceiling line
---	------	---

**Comments:**