CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215071

Address: 460 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Above Ceiling Inspection Michael Harkins Partial Wednesday, March 02,

2022

Corrective Action Required:

1 THE FOLLOWING Soffits and lid at dining ok

AREAS ARE - hard lids restrooms & water heater room ok to cover -

APPROVED

Corrective Action Required:

2 Miscellaneous - FIRE CAULK CONDUIT FOR PHONE CABLES WEST WALL NEAR REAR OF

Correction KITCHEN PROVIDE ACCESS TO THIS AREA -

OK TO DROP CEILING TILE OTHER AREAS

Comments: