CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213323

Address: 3813 SW WALSH DR, LEES SUMMIT, MO 640823811 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Control Robb Popp Failed Wednesday, March 02,

2022

Corrective Action Required:

1 DCM1 ESC EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE

REQUIRED NO PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.

FURTHER INSP

Corrective Action Required:

2 DCM2 ESC DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS

DEFICIENT UNTIL ADEQUATE EROSION CONTROL PROVIDED.

INSTALLATION -MAINTAIN SILT FENCE AT PERIMETER, MAINTAIN GRAVEL FILTER WITH 6" LIFT

OF 3/4' GRAVEL TO HOUSE, CLEAN DEBRIS FROM STREETS

Comments: