CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210628

Address: 2106 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Michael Harkins Failed Wednesday, March 02,

Residential 2022

Corrective Action Required:

1 Miscellaneous NO Rated assembly inspection on record

Correction (verify 5/8 type x & screw pattern)

Obtain lawn irrigation permit & submit back flow certification

Driveway inspection pending Complete retaining wall back yard Provide final grade, sod, splash blocks

Remove trash from window well expose drain Sump shall discharge 36" from foundation

Seal top of exterior light fixtures

Provide lock out device at service panel

for oven & microwave

Comments: