

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Failed	Wednesday, March 02, 2022

Corrective Action Required:

1 Misc

PRE FINAL AL BUILDING

****EAST WING UNITS ONLY**

-PROVIDE AFCI PROTECTION PER 210.12

-PROVIDE GFCI PROTECTION AT ALL RECEPTACLES WITHIN 6' OF KITCHEN SINK

-COMPLETE GRAB BARS AT ADA ROOMS

Comments: