

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211467
Address: 160 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, March 03, 2022

Corrective Action Required:

1	Miscellaneous Correction	- Complete plumbing penetration at master tub , fire block - Fire block penetration of gas line upstairs mechanical room - Add nails to straps at top plate upstairs, all
---	--------------------------	---

OK TO INSULATE

Comments: