

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213319
Address: 1418 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|--------------------------|
| All Rough Inspection - Residential | Shawn Hoffman | Failed | Thursday, March 03, 2022 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -connect and screw HVAC duct above 1st floor bath -vent all bath exhaust fans to exterior ,1st floor bath |
| | | -Provide missing truss hangers at hips |
| | | OK to insulate |

Comments: