

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216532  
Address: 1812 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Residential</b>	Shawn Hoffman	Failed	Thursday, March 03, 2022

Corrective Action Required:

2	Misc	- No access to basement floor -lid covering connections - compression joint not conforming with ASTM D2949 or ASTM F1488
---	------	--

**Comments:**