

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213784  
Address: 2617 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, March 03, 2022

Corrective Action Required:

1	Misc	-fire block south end furr down in garage -connect GEC to middle grounded bus bar -Secure fire blocking insulation in place -fire block north basement wall -complete dryer vent wall and fire block -complete attic access -add support for ridge above living room/kitchen wall -receptacle required right of back door wall space greater than 2'
---	------	---

**Comments:**