

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204715
Address: 1820 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, March 04, 2022

Corrective Action Required:

1 Misc

- Provide engineer report for truss repair above stair
- Extend supply air duct in unfinished basement to ceiling level
- Have engineer address CSPF walls at breakfast and master bedroom not constructed per plan

****DO NOT COVER AREAS STILL IN NEED OF INSPECTION**

Comments: