



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100063, Building Permit - Commercial  
Address: 3902 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Wednesday, November 10, 2010

### Corrective Action Required

1 E250.50 Grounding  
Electrode System

EXPOSE GROUNDING CONNECTIONS TO 2 GROUNDING RODS

### Corrective Action Required

2 MISC

SERVICE ENTRANCE CONDUCTORS BENDING RADIUS IS LESS  
THAN 5X CONDUCTOR RADIUS

\*I WILL GET BACK WITH YOU ON THIS AFTER I TALK TO PUBLIC  
WORKS INSPECTOR

### Comments: