





March 4, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

**RE: Field Issue of holdown device for Lot #101 Manor at Stoney Creek – 4417 SW Tanzanite Circle
Lee's Summit, MO 64082 – Permit # PRRES20212071**

This letter addresses the holdown device for Lot #101 Manor at Stoney Creek.

- 27" length of CS- WSP panel shall be installed as shown below at bedroom #1.
- Install holdown device for end condition #2 per manufacturer's specs as shown in image below, attached to king stud for daylight window header.



Sincerely,

A handwritten signature in blue ink, appearing to read "Bradley Huxol".

Bradley Huxol, PE

