



CITY OF LEE'S SUMMIT WATER MAIN INSPECTION

DATE: 11-10-2010

SUBDIVISION / PROJECT:

St. Lukes Bldg. F

TEMPERATURE: 70°

INSPECTOR: Bill Lynn / Bart Reese

ENGINEER: Shafer, Kline, and Warren

CONTRACTOR: Ike Dunn / P-1 Plumbing Company

SIZE OF PIPE: 6"

TYPE OF PIPE:

DIP

C900

EMBEDMENT: 3/4' clean rock

POLY WRAP:

NUMBER OF VALVES: 2

MANUFACTURER: APC

NUMBER OF FIRE HYDRANTS: 0

MANUFACTURER:

LENGTH OF MAIN EXTENTION TESTED: X

PRIVATE

PUBLIC

LENGTH OF FIRE LINE TESTED: 124' PRIVATE

DATE CHOLORNATED: 11-9-2010

DATE FLUSHED: 11-10-2010

HYDROSTATIC TEST RESULTS: 200 PSI

2 HRS.

DATE COLIFORM TEST PASSED: N/A

NUMBER OF SAMPLES:

REMARKS: BFU was constructed so coliform / water samples were not required.