

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20203845  
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Failed	Monday, March 07, 2022

Informational:	
1 Misc	-S100 OK FOR USE TO STORE EQUIPMENT
Partial Correction:	
2 Misc	Mike Weisenborn 09/29/2021 3:48 PM

Meet on site with Mike Weissenbach of the Fire Department to determine if the NW ball field could be utilized for the senior night game on October 4th. All life safety, access and parking requirements are being met for this location. Protective fencing is being installed to separate the construction area off. Portable facilities will be provided. Staff will be on site to provide additional safety.

The NW field is being released to be used for its intended purposes in the afternoon and early evening on Monday, October 4th, 2020.

Mike Weisenborn 03/07/2022 10:20 AM

City staff has completed additional inspections on the North Athletic Complex and the fields have been released to be used for their intended purposes. In addition to Storage S100, the following areas have been released to be used for their intended purposes.

S102 Visitor Changing Room

S103 Coaches Office

S105 Locker

S108 Home Changing Room

S111 Concessions has been released for the sale of items that do not require approval and a food handling license from the Jackson County Health Department.

All other areas (areas with plumbing fixtures) have not been released until water and sanitary is provided to the facility.

Temporary facilities shall be provided at anytime the facility is in use.

**Corrective Action Required:**

3 Misc

2/28/22 INSPECTION OF REMAINING FIELDS AND NORTH ATHLETIC COMPLEX FOR TCO

-PROVIDE PERMANENT SIGNAGE AT ELECTRICAL ROOM DOOR

-PROVIDE ANTI SIPHON DEVICE AT HOSE BIB

-COMPLETE WATER AND SANITARY

**Comments:**