

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20202637  
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Monday, March 07, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	2 EAST EXTERIOR CANOPIES-OK NORTH EXTERIOR CANOPY-OK  -SOFFITS AT: CLEAR STORY A100, B100A -HARD LIDS AT A213, B114, 121A, B113, C100A ,,B115,B117,C101A,C10,C10A,C129,C127,C121,C115D,C102-C104, C208, C214, C20  BUILDING A: A111,A112,A113, A100A,A100C,,A13,A110B,A101, A103, A104, A105, A106 A108,A108A,A110,A110A,117A,117B,118,118B A202, 203, 204, 205, 207, 208, 209, 210,21,200A,23,24,220A  BUILDING B: 101-103, 105-108, 110, 110A, 111,112, 117,118, 121, 121C, 122, 201-206, 208, 209, 211, 212, 214A, 215, 216, 216A, CORRIDORS EXCEPT AT B10 AND AT RATED ASSEMBLIES  **B113,B115, B121C, B121D, B122, B121, B121B, B120, B119 B212, B201, B203, B204-OK FOR BORDERS ONLY  BUILDING C: 101,101A,106-109, 111-113, 119, 120, 122-126, 128-131, 201-204, 211, 212, ,115-115C, 217A-217D, 219-219C, ALL CORRIDORS EXCEPT AT RATED
---	----------------------------------	---

ASSEMBLIES

\*\*C102, C104, C115A, C115B, C115C ,C117, C118, C119,C210, C206, C207  
OC216, C216B,OK FOR BORDERS ONLY

AREA D

- 1/27/22 HARD LIDS: D103 MEDIA CENTER, D101 A la carte counter, G108D -

\*\*D110A -OK FOR BORDERS ONLY

AREA E:

-E114B, E115, E118, E117B

-E10 CORRIDOR HARD LID SOFFITS

\*\*E114A, E117A, E123, E125, HARD LID OUTSIDE E123&124 -OK FOR BORDERS  
ONLY

AREA G: 102,103,107,108,108B,108F OK FOR BORDERS ONLY

Corrective Action Required:

2 Misc

A218, A218A- OPEN J BOXES

B210- OPEN J BOX

B214- OPEN J BOX, EXHAUST HOOD, MISSING (2) TIE WIRES AT MAIN

C206,207- COMPLETE FIRE RATED ASSEMBLY AT SEPARATION WALL

-SEAL PENETRATIONS, STENCILS AT FIRE SEPARATION WALLS THROUGHOUT  
CORRIDORS

-COMPLETE RATED ASSEMBLIES AT PENETRATIONS, TOP AND BOTTOM AND  
STENCILS AT VESTIBULES, CORRIDORS, AND ELEVATOR

**Comments:**