LIFE SAFETY SYSTEMS LLC

10143 Royalton Road, Suite R North Royalton, Ohio 44133 Phone (440) 888-7960 Fax (440) 888-7961

1 March 2022

City of Lee's Summit Building Department 220 SE Green Lee's Summit, MO 64063

Attn: Fire Alarm Plan Review Adjudication

Re: PetSuites (Animal Boarding) & Animal Hospital North- Fire Alarm System Plan Review Response 250 NW McNary Court Plan Review #Not Provided on Review Lee's Summit, MO 64086

This letter is being sent in response to the plan review dated 22 February 2022. Reviewers comments may be paraphrased for brevity, and only comments requiring a response is shown.

1. <u>COMMENT</u>: Provide plans that are stamped by a Missouri licensed PE.

Include equipment data sheets with submission.

RESPONSE: Plan shall be furnished to a Missouri PE for review/stamping.

Also; system data sheets were provided to the installation contractor/ applicant, and shall be reminded to submit them.

2. COMMENT: Heat detection is not required for this Use Group.

RESPONSE: The heat detection shown is elective coverage as allowed, and is desired by the Owners/Operators of these facilities, of which this is one of dozens that are being opened across the country under this general design. Elective coverage shall remain.

3. <u>COMMENT</u>: Remove all exterior notification appliances with the exception of the one required for exterior sprinkler system notification located over the FDC.

RESPONSE: External notification for employees within exterior fenced-in yards shall be removed. Only sprinkler notification device remains.

4. <u>COMMENT</u>: Provide audible notification appliances in boarding and daycare areas. Remove audible devices and replace with strobe-only devices within the surgical rooms.

RESPONSE: It is disappointing that Private Mode Signaling is not accepted at this facility as all others, however, these changes shall be made within the boarding/day care areas. The surgical areas were supposed to be strobe-only, and this plan error is now corrected.



Fire Alarm Plan Review Adjudication - Continued

PetSuites (Animal Boarding) & Animal Hospital North - Fire Alarm System Plan Review Response 250 NW McNary Court Plan Review #Not Provided on Review Lee's Summit, MO 64086

5. <u>COMMENT</u>: Ceiling fans depicted for shutdown do not appear to be HVLS fans, and therefore do not require shutdown.

RESPONSE: The plans now reflect the removal of any ceiling fan shutdowns.

We feel we have answered all comments and revised the fire alarm plans as required. Sincerely,

Damon G. Lewis, SET Operations Manager NICET Level IV #102567 Ohio Fire Alarm License # 54-47-1142 Ohio Fire Alarm Designer Certification #3191