

March 3, 2022

Distribution:

Craig Bruning **New Mark Homes** 5207 NW Crooked Road Parkville. Missouri 64152

Project:

Lot 125 Woodside Ridge 2111 NW Killarney Lane Lee's Summit, Missouri 64081

COMPLIANCE LETTER

This letter shall serve as verification that a representative(s) from Apex Engineers, Inc. ("Apex") performed a design review of the continuously sheathed portal frames on plan for the above referenced project.

Sheathing the interior side of the wall with 1/2" sheathing and fastening according to the detail will serve as an acceptable deviation from the detail in the construction drawings for the continuously sheathed portal frames.

To the best of our knowledge, information and belief, construction of the above phases will result in general conformance with the construction documents and approved changes.

LIMITATIONS

Apex has performed its services in a manner consistent with the standard of care and skill ordinarily exercised by members of our profession practicing under similar circumstances. The services of Apex should not be construed as Special Inspection services or full-time observation or inspection. Apex does not insure any result, nor does it warrant or guarantee that construction was properly performed. Even with constant monitoring, some construction defects may be missed. Apex is not responsible for the means, methods, sequences, and techniques of construction, since the contractor is solely responsible those and for the quality of work, adhering to plans, specifications, and appropriate codes, and repairing defects, deficiencies or omission, regardless of whether a defect is observed.

In addition, the scope our services does not include any evaluation of the building or site for job-site safety and/or hazardous conditions. The contractor is solely responsible for safety and compliance with IRC, IBC, and OSHA standards. Finally, Apex's scope of services does not include any environmental assessment (such as, but not limited to mold, mildew, presence of hazardous or toxic materials in the soil, surface water, ground water, etc.).

To the fullest extent permitted and allowed by law, Apex's client agrees to indemnify and hold harmless Apex and its owners, partners, officers, directors, employees, agents and sub-consultants, from and against all damage, liability and costs, including reasonable attorney's fees and cost of defense, arising out of the performance of these services, excepting only those damages, liabilities or costs attributable to the negligence or willful misconduct of Apex or its consultants.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards, Apex Engineers, Inc.

Connor J. Hobart Design Engineer

Bryce D. Crady Principal

Austin, TX 512 960-3722 Denver, CO 720 588-3222 Kansas City, MO 816 421-3222 NUMBER

PE-2006026494

Post 2022.

MINING ONAL ENGINEERING