

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213955

Address: 2103 SW OSAGE DR, LEES SUMMIT, MO 640822105 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, March 08, 2022

Corrective Action Required:

1	Misc	2103 -GAS LINE BOND REQUIRED -PRESSURE AT 0 PSI, MUST MAINTAIN 10 PSI FOR TEST
		2105 -GAS LINE BOND REQUIRED *PRESSURE OK*

Comments: