

## Backflow Prevention Assembly Test Data & Maintenance Report

Customer **Trumark Homes**

Service Address **202 NW Ambersham**

Location of Backflow Assembly on Property **Front Yard by Water Meter**

Date of Test <b>12-14-2021</b>	Time 10 : 30 AM <input checked="" type="checkbox"/> PM <input type="checkbox"/>	Supply Pressure <b>90</b> LBS	Air Gap (2 x Supply Diameter) Supply: <u>n/a</u> IN. Gap: <u>n/a</u> IN. <input type="checkbox"/> PASS <input type="checkbox"/> FAIL		
Type of Assembly <input checked="" type="checkbox"/> DC <input type="checkbox"/> RP <input type="checkbox"/> DCDA (Detector) <input type="checkbox"/> RPDA (Detector) <input type="checkbox"/> PVB* (See Bottom of Form)	Manufacturer <b>Febco</b>	Model <b>850</b>	Size <b>3/4</b>	Serial Number <b>HF-22912</b>	
Height off Floor <u>n/a</u> FT <u>n/a</u> IN	Protection From Freezing: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Flooding: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Supply Source <input checked="" type="checkbox"/> Public Potable Water <input type="checkbox"/> Both <input type="checkbox"/> Non-Potable Water (e.g., LAKE)		New Installation <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

Initial Test	Passed	Failed	Final Test After Repair	Passed	Failed
<b>Reduced Pressure Principle Assembly:</b>	<input type="checkbox"/>	<input type="checkbox"/>	<b>Reduced Pressure Principle Assembly:</b>	<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE opened at _____ PSID (2 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	RELIEF VALVE opened at _____ PSID (2 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
2nd CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>	2nd CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>
1st CHECK held in direction of flow _____ PSID (5 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	1st CHECK held in direction of flow _____ PSID (5 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
<b>Note: Failure of any of the above items, requires repair.</b>			<b>Note: Failure of any of the above items, requires repair.</b>		

Initial Test	Passed	Failed	Final Test After Repair	Passed	Failed
<b>Double Check Valve Assembly:</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>Double Check Valve Assembly:</b>	<input type="checkbox"/>	<input type="checkbox"/>
1st CHECK held in direction of flow <u>2.6</u> PSID (1 PSID or more)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1st CHECK held in direction of flow _____ PSID (1 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
2nd CHECK held backpressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2nd CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>
2nd CHECK held in direction of flow <u>2.4</u> PSID (1 PSID or more)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2nd CHECK held in direction of flow _____ PSID (1 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight	<input checked="" type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>
<b>Note: Failure of any of the above items, requires repair.</b>			<b>Note: Failure of any of the above items, requires repair.</b>		

<b>Application:</b> <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Fire Line <input type="checkbox"/> Fire Line By-Pass **Meter # _____ **Meter Read _____ <input type="checkbox"/> Point of Use	<b>Comments</b> <b>tested backflow working correctly</b>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------

<b>The Above Report is Certified to be True, Accurate and Complete</b>			
Tested By (Print) <b>Daniel J Coster</b>	(Signature)	Repaired by (Print)	(Signature)
Company <b>Pine Valley Lawn &amp; Landscape</b>	Final Test By (Print)	(Signature)	Date of Final Test
Missouri Certification Number <b>34-11206</b>	Expiration Date <b>9-30-2022</b>	Owner or Owner's Representative	Date

\*If an existing PVB is beyond repair and needs replacement, it should be replaced by a DC or RP to meet current State and City regulations.  
New PVB installations or replacements are not permitted.

\*\*METER # and METER READ for the fire line by-pass meter on detector assemblies are required.

Missouri State Regulation 10 CSR 60-11-010(6)(E) requires testers to report results of tests and inspections to the customer and water supplier.