

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212305
Address: 2122 NW KILLARNEY LN, LEES SUMMIT, MO 64081
Inspected On: Wednesday, March 09, 2022
Inspected By: Michael Harkins
Expiration Date: 04/15/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Wednesday, March 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	DRIVEWAY INSPECTION STILL PENDING PROVIDE SOD PROVIDE SPLASH BLOCKS SUMP SHALL DISCHARGE 36" FROM FOUNDATION
---	-----------------------------	---