

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210397
Address: 1721 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, March 09, 2022

Corrective Action Required:

1	Misc	-erosion control at front of lot need be in compliance before any further inspections -sod -address piers poured without inspection -check water meter at time of sod and other exterior items -address siding and roofing not completed at front of home -splash blocks and sump pump discharge to extend 36" from foundation -guard rail where required at front stoop where over 30" 36" out -window above master tub need be tempered -window at master back wall near patio door need be tempered -security screws at back patio doors -flood light at rear of home
---	------	--

Comments: