

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214597
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Wednesday, March 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide midpoint support vertical 2" & smaller dwv Fire caulk roof drains at wooden top plate Provide mid point support copper supply lines Fire blocking as required
---	-----------------------------	--

Comments: