

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213052

Address: 3819 SW WALSH DR, LEES SUMMIT, MO 640823817 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Wednesday, March 09, 2022

Corrective Action Required:

1	Misc	-clarify UL design for attic fire rated wall -repair damaged fire rock at rated separation wall -No ridge vent or openings of 4' fire rated play wood roof deck -screw all breakaway clips at firewall per detail, breakaway clip attachment and location per plans
---	------	--

Comments: