

March 9, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Clarification of CS-PF panels for Lot # 101 Hawthorne Ridge – 3101 SW Arbortree Dr. Lee's Summit, MO 64082 – Permit # PRRES20212956

- CS-PF panels at flex room shall be installed on interior side of front flex room wall.
- Install CS-PF per R602.10.
- Attach to bottom plate with structural screws at 3" oc.
- Attach bottom plate to floor joists with structural screws.





FIGURE R602.10.6.4 METHOD CS-PF—CONTINUOUSLY SHEATHED PORTAL FRAME PANEL CONSTRUCTION



Sincerely,



Bradley Huxol, PE