

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211211

Address: 628 NW WILLOW DR, LEES SUMMIT, MO 64081626 NW WILLOW DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|----------|--------------------------|
| Gas Service Inspection - Residential | Michael Harkins | Failed | Thursday, March 10, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | PROVIDE BOND GAS LINES (CSST) PRESSURE STEADY BOTH UNITS |
|---|--------------------------|--|

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 2 | Miscellaneous Correction | LAND BONDING IN BACKORDERED DISCONNECT |
|---|--------------------------|--|

Comments: