

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211211

Address: 628 NW WILLOW DR, LEES SUMMIT, MO 64081626 NW WILLOW DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Failed	Thursday, March 10, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	1ST LAYER TYPE X PARTY WALL, ATTIC, RAFTERS UNITS 626 & 628 2ND LAYER TYPE X UNITS 626 & 628
---	----------------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	FIRE CAULK ALL PENETRATIONS IN RATED WALL
---	--------------------------	---

Comments: