

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212682
Address: 1841 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, March 10, 2022

Corrective Action Required:

1	Misc	-Gas line bond need to be placed on steel line before first connection of CSST gas line
---	------	---

****PRESSURE OK****

Comments: