

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215067

Address: 2032 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822034 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822036 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822038 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Not Ready	Thursday, March 10, 2022

Corrective Action Required:

1	Misc	INSPECTION DENIED
		-FOOTING POURED WITHOUT INSPECTION
		- POST ADDRESSES
		-SNOW COVER PREVENT INSPECTION

Comments: