

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20212985  
Address: 1928 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, March 10, 2022

Corrective Action Required:

1	Misc	-Engineered soil report required
---	------	----------------------------------

Corrective Action Required:

2	Misc	MAINTAIN GRAVEL FILTER no further inspections until in compliance
---	------	---

- nail off all joist hangers completely above kitchen double lvl still missing nails
- fire back soffit end in bed 4 see dwv
- seal around return air above bed 4 ENTRY
- fire block dead space bed 4 and bed 4 closet (seal gaps)
- ground service to ufer (connect GEC to middle grounded bus bar or supply approved jumper to middle grounded bus bar )

**Comments:**