

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212985
Address: 1928 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, March 10, 2022

Corrective Action Required:

1	Misc	-Engineered soil report required
---	------	----------------------------------

Corrective Action Required:

2	Misc	MAINTAIN GRAVEL FILTER no further inspections until in compliance
---	------	---

- nail off all joist hangers completely above kitchen double lvl still missing nails
- fire block soffit end in bed 4 see dwv
- seal around return air above bed 4 ENTRY
- fire block dead space bed 4 and bed 4 closet (seal gaps)
- ground service to ufer (connect GEC to middle grounded bus bar or supply approved jumper to middle grounded bus bar)

Comments: