

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20212062  
Address: 2105 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Thursday, March 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide CS-PF exterior bracing at great room per plans ( 2018 IRC FIGURE R602.10.6.4 not done), exterior sheathing and nailing per design Address over notched girder stud pack at laundry room Complete shower drain master Provide (3) 2x6 under beam at patio SGD per plan
---	--------------------------	--

**Comments:**