

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216531
Address: 1708 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, March 10, 2022

Corrective Action Required:

1	Misc	NO INSPECTION PERFORMED
---	------	-------------------------

UNABLE TO INSPECT UNDERSLAB PLUMBING WITH SNOW COVER, RESCHEDULE WHEN CONDITIONS ALLOW FOR INSPECTION

Comments: