

Temporary Certificate of Occupancy

Permit #: PRRES20210397
Address: 1721 SW RIVER RUN DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, March 10, 2022
Inspected By: Mark Harding
Expiration Date: 4/28/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Temporary C of O	Thursday, March 10, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -erosion control at front of lot need be in compliance before any further inspections
-sod
-address piers poured without inspection
-check water meter at time of sod and other exterior items
-address siding and roofing not completed at front of home
-splash blocks and sump pump discharge to extend 36" from foundation
-guard rail where required at front stoop where over 30" 36" out
-window above master tub need be tempered
-window at master back wall near patio door need be tempered
-flood light at rear of home |
|---|------|--|

