

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211944
Address: 2354 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, March 11, 2022

Corrective Action Required:

1 Misc

- seal penetrations at fire place for csst,low voltage & water
- support Dwv above owners entry bath
- add stud at center return air in owners entry bath load bearing wall
- remove covering for covered front and back patio so show framing for inspection
- provide protection for dwv at hvac chase

Comments: