CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210399

Address: 4524 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Failed Friday, March 11, 2022

Residential

Corrective Action Required:

1 Misc -Final driveway inspection required, contact development services to

schedule

-Final grade and sod

-remove all construction debris/rebar from lot

-splash blocks at all downspout and sump pump discharge locations, min 36"

discharge from foundation
-install deadbolt lock front door

-Install all outlets and cover plates/switches at kitchen

-Install spark rings kitchen counter outlets, more than 1/4" setback on non

combustible surface

-Handrail required at garage steps, 4 rises

-label all circuit breaker locations at service panel

-add breaker lockout for hardwired appliances

-complete rear deck install, stairs, handrail, guard rails, landing, etc

-handrail required at walkout/walk up stairs to patio area, depending on final configuration a guardrail might be required around wall if walking surface

-install exterior security light at rear, exposed NM at wall

-Due to conditions at time of inspection a full inspection has not been

performed for full exterior. Additional items might be added at reinspection

Comments: