

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212062
Address: 2105 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|-----------|------------------------|
| All Rough Inspection - Residential | Michael Harkins | Not Ready | Monday, March 14, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | Provide CS-PF exterior bracing at great room per plans (2018 IRC FIGURE R602.10.6.4 not done), exterior sheathing and nailing per design (3" nailing pattern not done) Address over notched girder stud pack at laundry room (studs still notched) Complete shower drain master Provide (3) 2x6 under beam at patio SGD per plan (not done) |
|---|--------------------------|---|

Comments: