

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Monday, March 14, 2022

Informational:
1 Misc R&E Concrete had forms placed and aggregate was present and compacted. They were using KCM MB mix and I informed them about using white cure too. RP 3-4-22

Informational:
2 Misc Finished driveway meets LS spec. RP 3-14-22

Comments: