

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220499  
Address: 1211 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Khanh Nguyen	Failed	Monday, March 14, 2022

Corrective Action Required:

1	Misc	-Submit changes to plumbing plan -Support ejector pump 2" pvc at every 4 ft and slope toward drain -In-wall not inspected. Picture shown damaged studs without protection for plumbing. Uncover all plumbing for inspection -Under-slab plumbing was not inspected by city prior to cover. Floor receptor trap must be vented -Vertical to horizontal connection cannot be a sanitary tee fitting
---	------	---

**Comments:**