

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191614  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Partial	Monday, March 14, 2022

Corrective Action Required:

1 Misc

PRE FINAL AL BUILDING

**\*\*EAST WING UNITS ONLY**

- PROVIDE AFCI PROTECTION PER 210.12
- 107 NOT READY
- 109 FIRE CAULK MC IN CLOSET
- 110 FIRE CAULK THERMOSTAT WIRE
- 112 MISSING ADA CABINET IN KITCHEN
- 117 ANTI SIPHON DEVICE AT MOP SINK, PROVIDE 1" CLEARANCE ABOVE RIM OF SINK FOR DRAINS

**\*\*\*MC UNITS ONLY**

- PROVIDE AFCI PROTECTION PER 210,12
- 16 PROVIDE SPARK RING AND CORRECT GAP AT RECEPTACLE
- 6 FIRE CAULK HVAC
- 1 FIRE CAULK THERMOSTAT WIRE
- STORAGE CLOSETS- REMOVE TAPE ETC. FROM SPRINKLER HEADS, SEAL ALL PENETRATIONS
- CORRIDORS- FIRE CAULK AROUND ALL SPEAKERS IN CEILING
- PROVIDE WORKING SPACE AT ELECTRICAL PANEL IN CORRIDOR CLOSET

**Comments:**