CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204198

Address: 125 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Tuesday, March 15, Occupancy Inspection - Codes Shawn Hoffman Failed

Residential 2022

Corrective Action Required:

1 Miscellaneous - irrigation permit and back flow certification if installing

> Correction - Final grading and sod

> > - Splash blocks

- Sump discharge 36" from foundation

- Seal exterior penetrations

- Provide secondary lock on owner entry back door

- Provide secondary lock on front door

- Provide spark rings at kitchen counter outlets - Fire block penetration for gas line in garage

- Label all non- GFCI outlets

- Provide ladder for basement Egress window

- Complete install of water heaters, no Bvent, no gas.

- Security screws in doors

MAINTAIN EROSION CONTROL

Corrective Action Required:

Miscellaneous No inspection done 3/15/22

> Correction - no erosion control

> > - no secondary lock on front door

Did not go in.

Comments: