



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No: PRCOM20212128	Date: March 15, 2022
Project Title: MID-CONTINENT PUBLIC LIBRARY - OLDHAM BRANCH - ADDITION	Applicant:
Location: 150 NW OLDHAM PKWY, LEES SUMMIT, MO 64081	PROGRESSIVE ELECTRONICS INC 6102 ARLINGTON AVE RAYTOWN, MO 64133
Type of Work:	
Occupancy Group: B	Primary: (816) 765-5750
Description: ADDITION TO EXISTING LIBRARY INCLUDING INTERIOR ALTERATIONS	
Construction Type: Type IIB (Unprotected)	
Map Page:	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Verified At Inspection)
Call (816)969-1300

2. (Informational Purposes)
Mount the outside horn/strobe by the FDC.

Alarm Plan Review

Reviewed By: Jim Eden

Pending

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Coordinate with the sprinkler contractor and schedule a test. Call (816) 969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.