

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

Permit #: PRRES20204977  
Address: 202 NW AMBERSHAM DR, LEES SUMMIT, MO 64081  
Inspected On: Tuesday, March 15, 2022  
Inspected By: Michael Harkins  
Expiration Date: 04/15/2022

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Temporary C of O	Tuesday, March 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	Complete sod at rear driveway Provide handrail at retaining wall at rear garage per retaining wall plans, walking surface within 5' of drop over 30" to grade
---	-----------------------------	---